

REGIONAL WATER TESTING LAB, AMRITSAR

New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

To,

Principal Mahant Kaushal Dass DAV Public School Neshta Attari Amritsar
Mahant Kaushal Dass DAV Public School Neshta Attari Amritsar

No.: RWTLASR/2324/00060 Dated : 18/05/2023

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 5709 Dated: 08/05/2023


As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 10/05/2023. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Amritsar.

D/A : Test Report



**Authorized Signatory
For, Regional Water Testing Lab, Amritsar**

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com




TEST REPORT

Name & Address of Customer : Principal Mahant Kaushal Dass DAV Public School Neshta Attari Amritsar Mahant Kaushal Dass DAV Public School Neshta Attari Amritsar		Customer Reference No.	No : 5709 Dated : 08/05/2023
		Sample Submitted by	Mr. Rajesh
		Date of Sample Receipt	10/05/2023
		Analysis Starting Date	10/05/2023
		Analysis completion Date	11/05/2023
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC981523000000254F	Sample Type :	Water
Test Report No.:	RWTLASR/2324/00060	Date of Issue :	18/05/2023
Registration no.:	RWTLASR/REG2324/01149	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Neshta Attari Amritsar (250 ft) / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Amritsar
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.85	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993) Electrometric Method
2	Colour	1	5	15	CU	IS 3025 (Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 - 2018) (Second Revision)
4	TDS	294	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
5	Turbidity	0.74	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
6	Alkalinity	312	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
7	Hardness	244	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
8	Calcium	56.11	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium	25.27	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
10	Chloride	21.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

- The results apply to the sample as received only.
- The sample will be destroyed after retention time unless otherwise specified specially.
- This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
- Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
- * Value not available or test not performed for this parameter.
- Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%


Mr. Pankaj Kumar
 Quality Manager
 Authorized Signatory
 For, Regional Water Testing Lab, Amritsar

----- End of the Test Report -----



OFFICE OF CIVIL SURGEON, AMRITSAR

PHONE 0183 2211864

E-MAIL:- nrhmamritsar@gmail.com



No.SSI/CS/ASR/2023/.....20.....

DATED;...26/05/2023.....

Certificate of Cleanliness and Sanitation

This Is To Certify That We Have Inspected The Premises Of MAHANT KAUSHAL DASS DAV PUBLIC SCHOOL NESHTA (ATTARI) , AMRITSAR On 25/05/2023 After Inspecting Their Class Rooms And Toilets. We Certify That Their Cleanliness And Sanitation is Satisfactory. Facility of portable water with R.O. is also available.


Civil Surgeon ,Amritsar