

Ref.No.280

Dated: 23-2-2021

## SANITATION CERTIFICATE

I KAMALJIT SINGH, Executive Officer do hereby certify that Guru Nanak Dev DAV Public School, Bhikhiwind has provided sanitary arrangement in good condition, has safe drinking water facilities for the students and the staff members, is maintaining the hygienic sanitation condition in the school building & the campus as per the norms & is fit for the purpose of running this School in the public health point of view.

This **certificate** is issuing on the base of written request from Guru Nanak Dev DAV Public School, Bhikhiwind and personnel findings on inspection by the under signed on 23-02-2021

*Kamaljit Singh*  
ਕਾਮਲਜ ਸਿੰਘ  
ਨਗਰ ਪੰਚਾਇਤ, ਭਿਖੀਵਿੰਡ  
Signature with Seal

Name S Kamaljit Singh

Designation Executive Officer

Hi Tech Multi District Water Testing Laboratory.  
Water Supply & Sanitation Complex,  
Near Jaura Phatak Amritsar.

387

ANALYSIS REPORT FOR THE PHYSICAL & CHEMICAL AND BACTERIOLOGICAL  
EXAMINATION OF THE WATER SAMPLE

Particulars of Sample

1. Name of the Place: Guru Nanak Dev DAV Public School Block: Bhikiniwal.
2. Source of the sample: Tubewell
3. Whether water chlorinated: -
4. Date of Collection: 16-2-2021
5. Name and designations of the officer who collected Sample: Principal.
6. Date and Time of Commencing of Examination: 17-2-2021

CHEMICAL TEST REPORT

Sr. No.	TEST	DESIRABLE LIMIT	PERMISSIBLE LIMIT	RESULT
1	Turbidity (NTU)	5.0	10	0.1
2	Color (Physically)			Colorless
3	pH	6.5 to 8.5	No Relaxation	7.1
4	Total Dissolved Solids, PPM	500	2000	180
5	Alkalinity (as calcium carbonate) mg/L	200	600	130
6	Total Hardness (as Ca Co) mg/L	200	600	120
7	Residual Chlorine mg/L	0.2	1.0	-
8	Iron mg/L	0.3	No Relaxation	0.15
9	Flourides (as F) mg/L	1.0	1.5	-
10	Nitrate (as $\text{NO}_3$ ) mg/L	45	No Relaxation	-
11	Bacteriological Examination	After 24 hrs to 48 hrs		
	Total Coliform			
	E.Coli			

The water is Potable/ ~~Not Potable~~ according to the parameter tested above.

Chemist  
Hi Tech Multi Distt.  
Water Testing Laboratory  
Deptt. Of W/S & Sanitation,  
Amritsar.

1. Sample is not drawn by us unless otherwise stated.
2. Sample consumed in Testing.